

Flood Zone 3 Factsheet

East Anglia (East)

Oct 2017 - v.6

This factsheet provides information to assist with the preparation of a Flood Risk Assessment (FRA) in support of development proposals reviewed by the East Anglia (East) teams, based at Ipswich. It should be read alongside the Environment Agency's general FRA advice ([FRA Guidance note 3](#)). For information relating to proposals managed by East Anglia (West) teams based at Brampton, please contact: planning.brampton@environment-agency.gov.uk.

This factsheet covers issues relating to FRAs only and does not address other matters we may take into account when considering development proposals (e.g. proximity to a watercourse, contaminated land, Water Framework Directive and biodiversity requirements). For further information on those issues, please contact: planning.ipswich@environment-agency.gov.uk

Sequential Test and Exception Test

The Local Planning Authority (LPA) will need to be satisfied that the proposed development passes the flood risk Sequential Test, and if applicable, the first part of the Exception Test, in line with requirements of the National Planning Policy Framework (NPPF). We therefore strongly suggest you speak to them prior to commencing work on an FRA. Information regarding the [aim of the Sequential Test](#), [applying the Sequential Test](#) and the [Exception Test](#) can all be found in the Practice Guide supporting the NPPF.

Inappropriate development

[Table 2](#) of the Practice Guide categorizes developments according to their vulnerability and [table 3](#) sets out which vulnerabilities are inappropriate in Flood Zone 3. You should be aware that we are likely to object in principle where it is indicated that a development is not compatible in Flood Zone 3. Please note that Flood Zone 3b is defined by the Local Planning Authority's Strategic Flood Risk Assessment, or by the 5% (1 in 20 year) modelled flood outlines and levels held by the Environment Agency.

More detail on what should be in the FRA (additional to that highlighted in Guidance Note 3):

The FRA should assess all sources of flooding and provide sufficient information on the characteristics of flooding at the site, such as frequency, depth, velocity, speed of onset, and duration. As a minimum the FRA needs to assess the flood risk on site by comparing our modelled flood levels with a GPS verified topographical survey of the site to determine the anticipated flood depths during the 5% (1 in 20), 1% / 0.5% (1 in 100 / 200) (design) and 0.1% (1 in 1000) (extreme) events including allowances for climate change. Climate change allowances can be found on [our website](#). If the area is protected by defences then the FRA should consider both the actual flood risk to the site through overtopping of the defences, and the residual risk posed by the defences being breached.

- **Sequential approach on site**

If the site contains a range of Flood Zones, the sequential approach should be applied within the site to direct development to the areas of lowest flood risk. If it isn't possible to locate all development in Flood Zone 1, then the most vulnerable elements should be located in the lowest risk parts of the site.

- **Finished Floor Levels**

Proposals for 'more vulnerable' development should include floor levels set no lower than 300 mm above the level of any flooding that would occur if defences were overtopped in a 1% / 0.5% flood event (including allowances for climate change). Safe refuge should also be provided above the 0.1% undefended/breach flood level. We are likely to raise an objection where these requirements are not achieved.

We recommend 'less vulnerable' development also meets this requirement to minimize disruption and costs in a flood event. If this is not achievable then it is recommended that a place of refuge is provided above the 0.1% flood level. Where safety is reliant on refuge it is important that the building is structurally resilient to withstand the pressures and forces (hydrostatic and hydrodynamic) associated with flood water. The LPA may need to receive supporting information and calculations to provide certainty that the buildings will be constructed to withstand these water pressures.

- **Safe Access**

During a flood, the journey to safe, dry areas completely outside the extent of a 1% / 0.5% flood event (including allowances for climate change), should not involve crossing areas of potentially fast flowing water. Those venturing out on foot in areas where flooding exceeds 100 millimetres or so would be at risk from a wide range of hazards, including, for example unmarked drops, or access chambers where the cover has been swept away. Safe access and egress routes should be assessed in accordance with the guidance document '[FD2320 \(Flood Risk Assessment Guidance for New Developments\)](#)'.

- **Emergency Flood Plan**

Where safe access cannot be achieved, or if the development would be at actual flood risk or residual risk of flooding in a breach, an emergency flood plan must be provided. The plan should deal with matters of evacuation and refuge, and should demonstrate that people will not be exposed to flood hazards. The emergency flood plan should be submitted as part of the FRA and will need to be agreed with the Local Planning Authority.

- **Flood Resilience / Resistance Measures**

To minimize the disruption and cost implications of a flood event we encourage development to incorporate flood resilience/resistance measures up to the extreme 0.1% climate change flood level.

Information on preparing property for flooding can be found in the documents '[Improving the Flood performance of new buildings](#)' and '[Prepare your property for flooding](#)'.

- **Betterment**

Every effort should be made by the applicant to improve the flood risk to the local area, especially if there are known flooding issues. Opportunities should also be taken to provide environmental enhancements as part of the design, for example naturalizing any rivers on the site with a buffer zone on both sides.

- **Increases in Built Footprint (excluding open coast situations)**

It will need to be shown that any increase in built footprint within the extent of a 1% flood event (including allowances for climate change), can be directly compensated for on a volume-for-volume and level-for-level basis to prevent a loss of floodplain storage. If there are no available areas for compensation above the design flood level and compensation will not be possible, then a calculation of the offsite flood risk impacts will need to be undertaken. If this shows significant offsite impacts then no increases in built footprint will be allowed. Further guidance on the provision of compensatory flood storage is provided in section A3.3.10 of the CIRIA document C624.

Flood Defence Consent

Flood Defence Consents now fall under the Environmental Permitting (England and Wales) Regulations 2010 system (EPR). You may need an environmental permit for flood risk activities if you want to do work in, under, over or within 8 metres of a fluvial river or any flood defence structure or culvert / 16m from a tidal river or any flood defence structure or culvert. New forms and further information can be found at: <https://www.gov.uk/guidance/flood-risk-activities-environmental-permits>.

Local policies and recommendations

You will need to demonstrate to the Local Planning Authority that the requirements of any local flood risk planning policies have been met and the recommendations of the relevant Strategic Flood Risk Assessment, Shoreline Management Plans and Catchment Flood Management Plans have been considered.

Further Information:

If you require the flooding information we hold for this site then please email our local Customers and Engagement Team: enquiries_eastanglia@environment-agency.gov.uk. For further details on our flood map products please visit our website at: www.environment-agency.gov.uk/research/planning/93498.aspx.